

INVITATION TO BID

Sealed bids for furnishing supplies and installation of the Ag Lift Station Rehab, FOB, City of Arkansas City, Kansas, will be received at the office of the City Clerk, Arkansas City, Kansas, until 3:00 p.m. on November 11, 2025 at which time the bids will be opened publicly, at the office of the City Clerk, 118 W. Central, and read aloud. Bids received after said time will be returned unopened.

Copies of the purchase specifications are on file and available for public inspection at the following office:

Kyle Blubaugh, Assistant Environmental Superintendent
City of Arkansas City
2929 N. 2nd Street
Arkansas City, KS 67005
(620) 441-4484

A bidder may withdraw any bid they have submitted at any time prior to the hour set for the closing of the bids provided the request for withdrawal is signed in a manner identical with the bid being withdrawn. No withdrawal or modification will be permitted after the hour designated for closing of bids.

The City of Arkansas City reserves the right to reject any or all bids and to waive any irregularities therein.

Please address outside of envelope as:

Kyle Blubaugh
City of Arkansas City
P.O. Box 778
Arkansas City, KS 67005

Ag Lift Station Rehab – ENVIRONMENTAL SERVICES

Or

Submit the bid document to the attached link which can also be found on the City of Arkansas City Website under Environmental Services Ag Lift Station Rehab Bid.

https://arkansascityks-my.sharepoint.com/:f/g/personal/kblubaugh_arkansascityks_gov/Ep3JcjmgoxDjOIEXntOxPcB6MAvQlOQ00BQo8SdXegVBg

Please address file as:

Ag Lift Station Rehab – ENVIRONMENTAL SERVICES

GENERAL REQUIREMENTS

GENERAL

These specifications have been written to describe minimum equipment and performance requirements to be supplied by the equipment manufacturer's representative bidding.

It will be necessary for all successful bidders to furnish all necessary and desirable information and instructions for the proper operation of the equipment by the employees of the City. The City reserves the right to accept and/or reject any and all bids, to waive any defects, irregularities, or specification discrepancies and to award the contract as Council deems to be in the best interest of the City.

DISCREPANCIES LISTED

Should any bidder have deviations from these specifications in their bid and cannot meet every requirement of these specifications, they shall submit a letter and attach it to the bid, explaining the deviation. Failure to do so will cause the bid to be rejected as being non-responsive.

MODEL

The bid submitted shall be for a new and current production model. All equipment shall be included with the bid.

FEDERAL AND STATE TAXES

The Arkansas City Wastewater Department is exempt from Federal and State Taxes. Tax-Exempt Entity Exemption Certificate available.

GUARANTEE

The bidder shall guarantee the equipment against failure due to defective material and workmanship. The vehicle must be repaired at the bidder's expense within this period when such action is necessary for the reasons stated above.

BID FORM

To the Mayor and City Commissioners
Arkansas City, Kansas

1. The undersigned, in compliance with your invitation to bid for furnishing, equipment and labor for installation FOB, City of Arkansas City, Kansas, having examined the purchase specifications and being familiar with all of the conditions surrounding the furnishing of this equipment and installation of equipment in accordance with the purchase specifications at the price stated below. This price shall cover all expenses incurred in performing the work required under the documents and of which this proposal is a part:

BID PRICE OF:

Manufacturer of Bid:

Pump Package & Rehab \$ _____

Model of Bid:

2. The undersigned finally proposes to deliver the equipment, and necessary labor for installation, FOB, City of Arkansas City, Kansas, no later than

_____.

3. Standard Manufacturer's Warranty. Please describe, briefly.

4. The bidder agrees that this bid shall be good and may not be withdrawn for a period of 30 calendar days after the scheduled closing time for receiving bids.

Signed this _____ day of _____, 20_____.

Bidder _____

Address _____

By (print) _____

(signature) _____

Title _____

Ag Lift Station Rehab BID SPECIFICATIONS

Yes No

Install two OEM rebuild kit for Gorman Rupp Model T3A3-B (S/N: 1168072). Kit must contain all components required for full overhaul (e.g., seals, gaskets, o-rings, wear plates, bearings, impeller hardware).using existing bases, motors and couplings () ()

Keep one pump operational when installing the rebuild kit on the other pump. ... () ()

Install two new wafer check valves with external arms and springs. () ()

Install two new plug valves to replace existing three way valve..... () ()

Sand and repaint existing pump housing with Rust-Oleum oil based white paint () ()

Sand and repaint existing pump bases with Rust-Oleum oil based dark blue paint () ()

Install all new piping needed to complete installation from suction connection through discharge connection and paint with Rust-Oleum oil base, dark blue paint () ()

Install and connect Axial down blast exhaust fan to existing roof penetration () ()

Site clean up, equipment start-up and training as needed..... () ()

This is a turnkey project. If any portion of the scope cannot be provided by the contractor, that portion will be identified and competitively bid out separately to ensure completion. () ()

*If No is selected on any of the SPECIFICATIONS please provide an alternative on the line below

